



EIGHT POINT WIND ENERGY CENTER

Case No. 16-F-0062

1001.39 Exhibit 39

Wastewater Interconnection

Contents

Exhibit 39: Wastewater Interconnection 1

Exhibit 39: Wastewater Interconnection

This Exhibit is not applicable to the Eight Point Wind Energy Center, as there are no wastewater interconnections (no connection to municipal sewers) included in the proposed Project.

Wastewater Generated During Construction

The use of portable toilets during the construction process means any wastewater generated will be collected and removed off-site for treatment by a local contractor.

Wastewater Facilities for O&M Building

It is anticipated that an individual on-site wastewater treatment system (e.g., septic system) will be installed for the Operations and Maintenance (O&M) building to treat any wastewater generated. The building will have a restroom and will include a sufficiently sized septic system inspected and designed to code. Periodic removal and off-site treatment of septic sludge and other accumulation from the system's septic tank will likely be required every three to five years, depending on the frequency of wastewater processed.

Prior to and/or during the installation of the septic system, the Applicant will work with the Steuben County Department of Health and the Steuben County Soil & Water Conservation District, along with local septic system companies familiar with state and local requirements and conditions. The septic system will be constructed in accordance with the standards set forth by the New York State Department of Health (NYSDOH) in 10 NYCRR Part 75, Standards for Individual Onsite Wastewater Treatment Systems.